



BRUHAT BENGALURU MAHANAGARA PALIKE

Office of the Medical Officer OF Health Mahadevapura Zone, Bangalore - 560048

NO: BBMP/MOH/MDP/PR/87/2022-23

DATE:15/03/2023.

PERFORMA REGARDING NOC & SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


It is certified that an inspection team headed by **Dr.Rakesh N Medical Officer of Health** and **Mahesh Kumar.S, Sr.H.I.** (Name Of Officers with designation) from **BBMP Health Department** (Name of Department /Office) Inspected the **ORCHIDS THE INTERNATIONAL SCHOOL, #13, Survey #19, Ambalipura, Varthur Hobli, Sarjapura Road, Bangalore-560102.** (Name & Address of the school) on **15-03-2023** and found that the **ORCHIDS THE INTERNATIONAL SCHOOL,** (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central /state/U.T.Govt.

The Above NOC is Valid for the Period of up to 31.3.2024.

Signature with Seal :

Name

Designation


: **Dr.Rakesh N**
: Medical Officer of Health
ಆರೋಗ್ಯ ವೈದ್ಯಾಧಿಕಾರಿಗಳು
BBMP Mahadevapura Zone.
ಮಹದೇವಪುರ ವಲಯ
ಬೆಂಗಳೂರು

To,

**ORCHIDS THE INTERNATIONAL SCHOOL,
#13, Survey #19, Ambalipura,
Varthur Hobli, Sarjapura Road,
Bangalore-560102**

GOVERNMENT OF KARNATAKA

No:PHI/Water/BAC/87/23-24

Office of the Joint Director
Public Health Institute
Bangalore - 560 001

Dated: 20-05-2023

Report of Bacteriological analysis of Water / Effluent sample

Sample sent by:	Opinion							
	Sample No	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C Test	S.P.P	N.S.P.P	N.S.P.P & FC.
Orchids the International School Sarjapur Road. # 03 Sy no: 19 Ambalipura Varthuru Hobli. Bangalore - 102.	285	RO	NIL	-	-	SPP	-	-
Note: M.P.N Count: Most probable number of Bacteria per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E.Coli found.								

For Joint Director(Labs)
PUBLIC HEALTH INSTITUTE
Bangalore

Advice:

1. Sample.....

Need effective chlorination before use

2. Sample.....

Need to avoid possible source of fecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E coli count per 100ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or more